## Annual Water Quality Report Detected Sample Results (Water Quality Table) MOUNTIAN CREST DEVELOPMENT PWSID # 2640056

January 1, 2021 to December 31, 2021

Disinfection

| Contaminant/    | Annual             | Highest            | Lowest             | Compliance | MRDL<br>Allowed |  |
|-----------------|--------------------|--------------------|--------------------|------------|-----------------|--|
| Unit of Measure | Monthly<br>Average | Monthly<br>Average | Monthly<br>Average | Achieved   |                 |  |
| Chlorine, mg/L  | 0.71               | 0.88               | 0.62               | Yes        | 4.0             |  |

## **Radioactive Contaminants**

| Contaminant/                    | Date              | Violation    | EP 101<br>Level Detected |                | MCL                              | MCLG      | Source of Contamination   |  |
|---------------------------------|-------------------|--------------|--------------------------|----------------|----------------------------------|-----------|---|--|
| Unit of Measure                 | Tested            | Yes/No       |                          |                |                                  | (Goal)    |   |  |
| Gross Alpha, pCi/L              | 12/14/2016        | No           | ND                       |                | 15                               | <15       | Erosion of natural deposits   |  |
| Radium-226, pCi/L               | 12/14/2016        | No           | ND                       |                | <5                               | <5        | Erosion of natural deposits   |  |
| Radium-228,pCi/L                | 12/14/2016        | No           | ND                       |                | <5                               | <5        | Erosion of natural deposits   |  |
| Uranium,pCi/L                   | 9/13/2019         | No           | ND                       |                | 30,000                           | <30,000   | Erosion of natural deposits   |  |
| InOrganic Chemicals             | Date              | Violation    | Level f                  | Detected       | MCL                              | MCLG      | Source of Contamination   |  |
| Unit of Measure                 | Tested            | Yes/No       | E.P. 101                 |                | mg/L                             | (Goal)    |   |  |
| Barium,mg/L                     | 9/18/2018         | No           | 0.06                     |                | 2                                | <2        | Erosion of natural deposits.<br>Discharge of drilling wastes and<br>refineries. |  |
| Nickel,mg/L                     | 9/18/2018         | No           | ND                       |                | _                                |           |   |  |
| Nitrate mg/L                    | 3/11/2021         | No           | 0.34                     |                | 10                               |           |   |  |
| Nitrite,mg/L                    | 3/11/2021         | No           | ND                       |                | 1                                | <10       | Runoff from fertilizer; leaching<br>from septic tanks; erosion of               |  |
| Arsenic (IOC), mg/L             | 9/18/2018         | No           | ND                       |                | 0.01                             | <.01      | natural deposits.   |  |
| **Nitrate and Arsenic (IOC) Sam | ples Taken at ENT | RY POINT     |                          |                |                                  |           |   |  |
| Lead and Copper Rule Co         | mpliance Mon      | toring       |                          |                |                                  |           |   |  |
| Contaminant/Unit of<br>Measure  | Date Tested       | Action Level | MCLG                     | Level Detected | Number of<br>Sites<br>above A.L. | Violation | Likely Source of Contamination  |  |
| Copper/ppm                      | 7/26/2019         | 1            | <1.0                     | 0.825          | 0 out of 5                       | None      | Corrosion of household<br>plumbing systems, erosion of<br>natural deposits      |  |
|                                 |                   |              |                          |                |                                  |           |   |  |

Trihalomethanes/HaloAcetic Acids

Lead/ppm

| Contaminant      | Date      | Level Detected |  | Violation | MCL  |
|------------------|-----------|----------------|--|-----------|------|
| Unit of Measure  | Tested    | SITE 701       |  | Yes/No    | mg/L |
| Trihalomethanes  | 9/13/2019 | ND             |  | No        | 0.08 |
| Haloacetic Acids | 9/13/2019 | ND             |  | No        | 0.06 |

1.3

7/26/2019

<1.0

## 21 VOLATILE ORGANIC CONTAMINANTS (VOC'S) WERE NOT DETECTED IN 2019

N/D

0 out of 5

Corrosion of household

plumbing systems, erosion of

natural deposits

None

## INORGANIC CHEMICALS (IOC's) WERE NOT DETECTED IN 2021